

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/363/25	Model No.: MARQ-6-50%	Date: 19-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 363/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36201 To 36300 And 36205A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36205A and removed from the Lot/Batch							
36201	Pass	36202	Pass	36203	Pass	36204	Pass
36205	Pass	36206	Pass	36207	Pass	36208	Pass
36209	Pass	36210	Pass	36211	Pass	36212	Pass
36213	Pass	36214	Pass	36215	Pass	36216	Pass
36217	Pass	36218	Pass	36219	Pass	36220	Pass
36221	Pass	36222	Pass	36223	Pass	36224	Pass
36225	Pass	36226	Pass	36227	Pass	36228	Pass
36229	Pass	36230	Pass	36231	Pass	36232	Pass
36233	Pass	36234	Pass	36235	Pass	36236	Pass
36237	Pass	36238	Pass	36239	Pass	36240	Pass
36241	Pass	36242	Pass	36243	Pass	36244	Pass
36245	Pass	36246	Pass	36247	Pass	36248	Pass
36249	Pass	36250	Pass	36251	Pass	36252	Pass
36253	Pass	36254	Pass	36255	Pass	36256	Pass
36257	Pass	36258	Pass	36259	Pass	36260	Pass
36261	Pass	36262	Pass	36263	Pass	36264	Pass
36265	Pass	36266	Pass	36267	Pass	36268	Pass
36269	Pass	36270	Pass	36271	Pass	36272	Pass
36273	Pass	36274	Pass	36275	Pass	36276	Pass
36277	Pass	36278	Pass	36279	Pass	36280	Pass
36281	Pass	36282	Pass	36283	Pass	36284	Pass
36285	Pass	36286	Pass	36287	Pass	36288	Pass
36289	Pass	36290	Pass	36291	Pass	36292	Pass
36293	Pass	36294	Pass	36295	Pass	36296	Pass
36297	Pass	36298	Pass	36299	Pass	36300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory