

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/366/25	Model No.: MARQ-6-50%	Date: 19-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 366/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36501 To 36600 And 36505A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36505A and removed from the Lot/Batch							
36501	Pass	36502	Pass	36503	Pass	36504	Pass
36505	Pass	36506	Pass	36507	Pass	36508	Pass
36509	Pass	36510	Pass	36511	Pass	36512	Pass
36513	Pass	36514	Pass	36515	Pass	36516	Pass
36517	Pass	36518	Pass	36519	Pass	36520	Pass
36521	Pass	36522	Pass	36523	Pass	36524	Pass
36525	Pass	36526	Pass	36527	Pass	36528	Pass
36529	Pass	36530	Pass	36531	Pass	36532	Pass
36533	Pass	36534	Pass	36535	Pass	36536	Pass
36537	Pass	36538	Pass	36539	Pass	36540	Pass
36541	Pass	36542	Pass	36543	Pass	36544	Pass
36545	Pass	36546	Pass	36547	Pass	36548	Pass
36549	Pass	36550	Pass	36551	Pass	36552	Pass
36553	Pass	36554	Pass	36555	Pass	36556	Pass
36557	Pass	36558	Pass	36559	Pass	36560	Pass
36561	Pass	36562	Pass	36563	Pass	36564	Pass
36565	Pass	36566	Pass	36567	Pass	36568	Pass
36569	Pass	36570	Pass	36571	Pass	36572	Pass
36573	Pass	36574	Pass	36575	Pass	36576	Pass
36577	Pass	36578	Pass	36579	Pass	36580	Pass
36581	Pass	36582	Pass	36583	Pass	36584	Pass
36585	Pass	36586	Pass	36587	Pass	36588	Pass
36589	Pass	36590	Pass	36591	Pass	36592	Pass
36593	Pass	36594	Pass	36595	Pass	36596	Pass
36597	Pass	36598	Pass	36599	Pass	36600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory