

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/364/25	Model No.: MARQ-6-50%	Date: 19-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 364/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36301 To 36400 And 36305A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36305A and removed from the Lot/Batch							
36301	Pass	36302	Pass	36303	Pass	36304	Pass
36305	Pass	36306	Pass	36307	Pass	36308	Pass
36309	Pass	36310	Pass	36311	Pass	36312	Pass
36313	Pass	36314	Pass	36315	Pass	36316	Pass
36317	Pass	36318	Pass	36319	Pass	36320	Pass
36321	Pass	36322	Pass	36323	Pass	36324	Pass
36325	Pass	36326	Pass	36327	Pass	36328	Pass
36329	Pass	36330	Pass	36331	Pass	36332	Pass
36333	Pass	36334	Pass	36335	Pass	36336	Pass
36337	Pass	36338	Pass	36339	Pass	36340	Pass
36341	Pass	36342	Pass	36343	Pass	36344	Pass
36345	Pass	36346	Pass	36347	Pass	36348	Pass
36349	Pass	36350	Pass	36351	Pass	36352	Pass
36353	Pass	36354	Pass	36355	Pass	36356	Pass
36357	Pass	36358	Pass	36359	Pass	36360	Pass
36361	Pass	36362	Pass	36363	Pass	36364	Pass
36365	Pass	36366	Pass	36367	Pass	36368	Pass
36369	Pass	36370	Pass	36371	Pass	36372	Pass
36373	Pass	36374	Pass	36375	Pass	36376	Pass
36377	Pass	36378	Pass	36379	Pass	36380	Pass
36381	Pass	36382	Pass	36383	Pass	36384	Pass
36385	Pass	36386	Pass	36387	Pass	36388	Pass
36389	Pass	36390	Pass	36391	Pass	36392	Pass
36393	Pass	36394	Pass	36395	Pass	36396	Pass
36397	Pass	36398	Pass	36399	Pass	36400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory