

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/365/25	Model No.: MARQ-6-50%	Date: 19-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 365/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36401 To 36500 And 36405A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36405A and removed from the Lot/Batch							
36401	Pass	36402	Pass	36403	Pass	36404	Pass
36405	Pass	36406	Pass	36407	Pass	36408	Pass
36409	Pass	36410	Pass	36411	Pass	36412	Pass
36413	Pass	36414	Pass	36415	Pass	36416	Pass
36417	Pass	36418	Pass	36419	Pass	36420	Pass
36421	Pass	36422	Pass	36423	Pass	36424	Pass
36425	Pass	36426	Pass	36427	Pass	36428	Pass
36429	Pass	36430	Pass	36431	Pass	36432	Pass
36433	Pass	36434	Pass	36435	Pass	36436	Pass
36437	Pass	36438	Pass	36439	Pass	36440	Pass
36441	Pass	36442	Pass	36443	Pass	36444	Pass
36445	Pass	36446	Pass	36447	Pass	36448	Pass
36449	Pass	36450	Pass	36451	Pass	36452	Pass
36453	Pass	36454	Pass	36455	Pass	36456	Pass
36457	Pass	36458	Pass	36459	Pass	36460	Pass
36461	Pass	36462	Pass	36463	Pass	36464	Pass
36465	Pass	36466	Pass	36467	Pass	36468	Pass
36469	Pass	36470	Pass	36471	Pass	36472	Pass
36473	Pass	36474	Pass	36475	Pass	36476	Pass
36477	Pass	36478	Pass	36479	Pass	36480	Pass
36481	Pass	36482	Pass	36483	Pass	36484	Pass
36485	Pass	36486	Pass	36487	Pass	36488	Pass
36489	Pass	36490	Pass	36491	Pass	36492	Pass
36493	Pass	36494	Pass	36495	Pass	36496	Pass
36497	Pass	36498	Pass	36499	Pass	36500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory