

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/370/25	Model No.: MARQ-6-50%	Date: 20-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 370/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36901 To 37000 And 36905A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36905A and removed from the Lot/Batch							
36901	Pass	36902	Pass	36903	Pass	36904	Pass
36905	Pass	36906	Pass	36907	Pass	36908	Pass
36909	Pass	36910	Pass	36911	Pass	36912	Pass
36913	Pass	36914	Pass	36915	Pass	36916	Pass
36917	Pass	36918	Pass	36919	Pass	36920	Pass
36921	Pass	36922	Pass	36923	Pass	36924	Pass
36925	Pass	36926	Pass	36927	Pass	36928	Pass
36929	Pass	36930	Pass	36931	Pass	36932	Pass
36933	Pass	36934	Pass	36935	Pass	36936	Pass
36937	Pass	36938	Pass	36939	Pass	36940	Pass
36941	Pass	36942	Pass	36943	Pass	36944	Pass
36945	Pass	36946	Pass	36947	Pass	36948	Pass
36949	Pass	36950	Pass	36951	Pass	36952	Pass
36953	Pass	36954	Pass	36955	Pass	36956	Pass
36957	Pass	36958	Pass	36959	Pass	36960	Pass
36961	Pass	36962	Pass	36963	Pass	36964	Pass
36965	Pass	36966	Pass	36967	Pass	36968	Pass
36969	Pass	36970	Pass	36971	Pass	36972	Pass
36973	Pass	36974	Pass	36975	Pass	36976	Pass
36977	Pass	36978	Pass	36979	Pass	36980	Pass
36981	Pass	36982	Pass	36983	Pass	36984	Pass
36985	Pass	36986	Pass	36987	Pass	36988	Pass
36989	Pass	36990	Pass	36991	Pass	36992	Pass
36993	Pass	36994	Pass	36995	Pass	36996	Pass
36997	Pass	36998	Pass	36999	Pass	37000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory