

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/186/25	Model No.: KMCRQ-10	Date: 09-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 186/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01851 To 1860	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01851 To 1860 and removed from the Lot/Batch							
1851	Pass	1852	Pass	1853	Pass	1854	Pass
1855	Pass	1856	Pass	1857	Pass	1858	Pass
1859	Pass	1860	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory