

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/051/25	Model No.: KFMRQ-45	Date: 18-11-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 051/25	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 02501 To 2550 And 2505A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.2505A and which is removed from the batch (51st batch)							
2501	Pass	2502	Pass	2503	Pass	2504	Pass
2505	Pass	2506	Pass	2507	Pass	2508	Pass
2509	Pass	2510	Pass	2511	Pass	2512	Pass
2513	Pass	2514	Pass	2515	Pass	2516	Pass
2517	Pass	2518	Pass	2519	Pass	2520	Pass
2521	Pass	2522	Pass	2523	Pass	2524	Pass
2525	Pass	2526	Pass	2527	Pass	2528	Pass
2529	Pass	2530	Pass	2531	Pass	2532	Pass
2533	Pass	2534	Pass	2535	Pass	2536	Pass
2537	Pass	2538	Pass	2539	Pass	2540	Pass
2541	Pass	2542	Pass	2543	Pass	2544	Pass
2545	Pass	2546	Pass	2547	Pass	2548	Pass
2549	Pass	2550	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory