

HYDRO PRESSURE TEST

TC No.: HPT/A9/A50/RQ/034/25	Model No.: KFARQ-9-50%	Date: 26-08-2025
Type and Capacity of Extinguisher	: KFARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFARQ50%9 034/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03301 To 3400 And 3305A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3305A and removed from the Lot/Batch							
3301	Pass	3302	Pass	3303	Pass	3304	Pass
3305	Pass	3306	Pass	3307	Pass	3308	Pass
3309	Pass	3310	Pass	3311	Pass	3312	Pass
3313	Pass	3314	Pass	3315	Pass	3316	Pass
3317	Pass	3318	Pass	3319	Pass	3320	Pass
3321	Pass	3322	Pass	3323	Pass	3324	Pass
3325	Pass	3326	Pass	3327	Pass	3328	Pass
3329	Pass	3330	Pass	3331	Pass	3332	Pass
3333	Pass	3334	Pass	3335	Pass	3336	Pass
3337	Pass	3338	Pass	3339	Pass	3340	Pass
3341	Pass	3342	Pass	3343	Pass	3344	Pass
3345	Pass	3346	Pass	3347	Pass	3348	Pass
3349	Pass	3350	Pass	3351	Pass	3352	Pass
3353	Pass	3354	Pass	3355	Pass	3356	Pass
3357	Pass	3358	Pass	3359	Pass	3360	Pass
3361	Pass	3362	Pass	3363	Pass	3364	Pass
3365	Pass	3366	Pass	3367	Pass	3368	Pass
3369	Pass	3370	Pass	3371	Pass	3372	Pass
3373	Pass	3374	Pass	3375	Pass	3376	Pass
3377	Pass	3378	Pass	3379	Pass	3380	Pass
3381	Pass	3382	Pass	3383	Pass	3384	Pass
3385	Pass	3386	Pass	3387	Pass	3388	Pass
3389	Pass	3390	Pass	3391	Pass	3392	Pass
3393	Pass	3394	Pass	3395	Pass	3396	Pass
3397	Pass	3398	Pass	3399	Pass	3400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory