

HELIUM LEAK DETECTION TEST

TC No.: HLD/A4/K/HQ/018/25

Model No.: KFKHQ-4

Date: 22-09-2025

Type and Capacity of Extinguisher : KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.

Batch Number : KFKHQ4 018/25

Batch Quantity : 10 Nos.

Serial Numbers : 00171 To 180

Month of Manufacturing : Sep/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
171	Pass	172	Pass	173	Pass	174	Pass
175	Pass	176	Pass	177	Pass	178	Pass
179	Pass	180	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**