

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/041/25	Model No.: KFKHQ-9	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 041/25	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00401 To 410	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
401	Pass	402	Pass	403	Pass	404	Pass
405	Pass	406	Pass	407	Pass	408	Pass
409	Pass	410	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory