

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/042/25

Model No.: KFKHQ-9

Date: 04-10-2025

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 042/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 00411 To 420

Month of Manufacturing : Oct/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00411 To 420 and removed from the Lot/Batch							
411	Pass	412	Pass	413	Pass	414	Pass
415	Pass	416	Pass	417	Pass	418	Pass
419	Pass	420	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**