

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/297/25      | Model No.: KFARQ-6-90%                                          | Date: 27-12-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 297/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 29601 To 29700 And 29605A                                     |                  |
| Month of Manufacturing            | : Dec/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 29605A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 29601                                                         | Pass   | 29602    | Pass   | 29603    | Pass   | 29604    | Pass   |
| 29605                                                         | Pass   | 29606    | Pass   | 29607    | Pass   | 29608    | Pass   |
| 29609                                                         | Pass   | 29610    | Pass   | 29611    | Pass   | 29612    | Pass   |
| 29613                                                         | Pass   | 29614    | Pass   | 29615    | Pass   | 29616    | Pass   |
| 29617                                                         | Pass   | 29618    | Pass   | 29619    | Pass   | 29620    | Pass   |
| 29621                                                         | Pass   | 29622    | Pass   | 29623    | Pass   | 29624    | Pass   |
| 29625                                                         | Pass   | 29626    | Pass   | 29627    | Pass   | 29628    | Pass   |
| 29629                                                         | Pass   | 29630    | Pass   | 29631    | Pass   | 29632    | Pass   |
| 29633                                                         | Pass   | 29634    | Pass   | 29635    | Pass   | 29636    | Pass   |
| 29637                                                         | Pass   | 29638    | Pass   | 29639    | Pass   | 29640    | Pass   |
| 29641                                                         | Pass   | 29642    | Pass   | 29643    | Pass   | 29644    | Pass   |
| 29645                                                         | Pass   | 29646    | Pass   | 29647    | Pass   | 29648    | Pass   |
| 29649                                                         | Pass   | 29650    | Pass   | 29651    | Pass   | 29652    | Pass   |
| 29653                                                         | Pass   | 29654    | Pass   | 29655    | Pass   | 29656    | Pass   |
| 29657                                                         | Pass   | 29658    | Pass   | 29659    | Pass   | 29660    | Pass   |
| 29661                                                         | Pass   | 29662    | Pass   | 29663    | Pass   | 29664    | Pass   |
| 29665                                                         | Pass   | 29666    | Pass   | 29667    | Pass   | 29668    | Pass   |
| 29669                                                         | Pass   | 29670    | Pass   | 29671    | Pass   | 29672    | Pass   |
| 29673                                                         | Pass   | 29674    | Pass   | 29675    | Pass   | 29676    | Pass   |
| 29677                                                         | Pass   | 29678    | Pass   | 29679    | Pass   | 29680    | Pass   |
| 29681                                                         | Pass   | 29682    | Pass   | 29683    | Pass   | 29684    | Pass   |
| 29685                                                         | Pass   | 29686    | Pass   | 29687    | Pass   | 29688    | Pass   |
| 29689                                                         | Pass   | 29690    | Pass   | 29691    | Pass   | 29692    | Pass   |
| 29693                                                         | Pass   | 29694    | Pass   | 29695    | Pass   | 29696    | Pass   |
| 29697                                                         | Pass   | 29698    | Pass   | 29699    | Pass   | 29700    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**