

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/369/25	Model No.: MARQ-6-50%	Date: 20-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 369/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36801 To 36900 And 36805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36805A and removed from the Lot/Batch							
36801	Pass	36802	Pass	36803	Pass	36804	Pass
36805	Pass	36806	Pass	36807	Pass	36808	Pass
36809	Pass	36810	Pass	36811	Pass	36812	Pass
36813	Pass	36814	Pass	36815	Pass	36816	Pass
36817	Pass	36818	Pass	36819	Pass	36820	Pass
36821	Pass	36822	Pass	36823	Pass	36824	Pass
36825	Pass	36826	Pass	36827	Pass	36828	Pass
36829	Pass	36830	Pass	36831	Pass	36832	Pass
36833	Pass	36834	Pass	36835	Pass	36836	Pass
36837	Pass	36838	Pass	36839	Pass	36840	Pass
36841	Pass	36842	Pass	36843	Pass	36844	Pass
36845	Pass	36846	Pass	36847	Pass	36848	Pass
36849	Pass	36850	Pass	36851	Pass	36852	Pass
36853	Pass	36854	Pass	36855	Pass	36856	Pass
36857	Pass	36858	Pass	36859	Pass	36860	Pass
36861	Pass	36862	Pass	36863	Pass	36864	Pass
36865	Pass	36866	Pass	36867	Pass	36868	Pass
36869	Pass	36870	Pass	36871	Pass	36872	Pass
36873	Pass	36874	Pass	36875	Pass	36876	Pass
36877	Pass	36878	Pass	36879	Pass	36880	Pass
36881	Pass	36882	Pass	36883	Pass	36884	Pass
36885	Pass	36886	Pass	36887	Pass	36888	Pass
36889	Pass	36890	Pass	36891	Pass	36892	Pass
36893	Pass	36894	Pass	36895	Pass	36896	Pass
36897	Pass	36898	Pass	36899	Pass	36900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory