

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/377/25	Model No.: MARQ-6-50%	Date: 26-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 377/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 37601 To 37700 And 37605A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 37605A and removed from the Lot/Batch							
37601	Pass	37602	Pass	37603	Pass	37604	Pass
37605	Pass	37606	Pass	37607	Pass	37608	Pass
37609	Pass	37610	Pass	37611	Pass	37612	Pass
37613	Pass	37614	Pass	37615	Pass	37616	Pass
37617	Pass	37618	Pass	37619	Pass	37620	Pass
37621	Pass	37622	Pass	37623	Pass	37624	Pass
37625	Pass	37626	Pass	37627	Pass	37628	Pass
37629	Pass	37630	Pass	37631	Pass	37632	Pass
37633	Pass	37634	Pass	37635	Pass	37636	Pass
37637	Pass	37638	Pass	37639	Pass	37640	Pass
37641	Pass	37642	Pass	37643	Pass	37644	Pass
37645	Pass	37646	Pass	37647	Pass	37648	Pass
37649	Pass	37650	Pass	37651	Pass	37652	Pass
37653	Pass	37654	Pass	37655	Pass	37656	Pass
37657	Pass	37658	Pass	37659	Pass	37660	Pass
37661	Pass	37662	Pass	37663	Pass	37664	Pass
37665	Pass	37666	Pass	37667	Pass	37668	Pass
37669	Pass	37670	Pass	37671	Pass	37672	Pass
37673	Pass	37674	Pass	37675	Pass	37676	Pass
37677	Pass	37678	Pass	37679	Pass	37680	Pass
37681	Pass	37682	Pass	37683	Pass	37684	Pass
37685	Pass	37686	Pass	37687	Pass	37688	Pass
37689	Pass	37690	Pass	37691	Pass	37692	Pass
37693	Pass	37694	Pass	37695	Pass	37696	Pass
37697	Pass	37698	Pass	37699	Pass	37700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory