

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/378/25	Model No.: MARQ-6-50%	Date: 27-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 378/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 37701 To 37800 And 37705A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 37705A and removed from the Lot/Batch							
37701	Pass	37702	Pass	37703	Pass	37704	Pass
37705	Pass	37706	Pass	37707	Pass	37708	Pass
37709	Pass	37710	Pass	37711	Pass	37712	Pass
37713	Pass	37714	Pass	37715	Pass	37716	Pass
37717	Pass	37718	Pass	37719	Pass	37720	Pass
37721	Pass	37722	Pass	37723	Pass	37724	Pass
37725	Pass	37726	Pass	37727	Pass	37728	Pass
37729	Pass	37730	Pass	37731	Pass	37732	Pass
37733	Pass	37734	Pass	37735	Pass	37736	Pass
37737	Pass	37738	Pass	37739	Pass	37740	Pass
37741	Pass	37742	Pass	37743	Pass	37744	Pass
37745	Pass	37746	Pass	37747	Pass	37748	Pass
37749	Pass	37750	Pass	37751	Pass	37752	Pass
37753	Pass	37754	Pass	37755	Pass	37756	Pass
37757	Pass	37758	Pass	37759	Pass	37760	Pass
37761	Pass	37762	Pass	37763	Pass	37764	Pass
37765	Pass	37766	Pass	37767	Pass	37768	Pass
37769	Pass	37770	Pass	37771	Pass	37772	Pass
37773	Pass	37774	Pass	37775	Pass	37776	Pass
37777	Pass	37778	Pass	37779	Pass	37780	Pass
37781	Pass	37782	Pass	37783	Pass	37784	Pass
37785	Pass	37786	Pass	37787	Pass	37788	Pass
37789	Pass	37790	Pass	37791	Pass	37792	Pass
37793	Pass	37794	Pass	37795	Pass	37796	Pass
37797	Pass	37798	Pass	37799	Pass	37800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory