

**HYDRO PRESSURE TEST**

TC No.: HPT/MOD10/CA/RQ/183/25

Model No.: KMCRQ-10

Date: 09-12-2025

Type and Capacity of Extinguisher : KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.

Batch Number : KMCRQ10 183/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 01821 To 1830

Month of Manufacturing : Dec/25

| Sr. Nos.                                                             | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 01821 To 1830 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1821                                                                 | Pass   | 1822     | Pass   | 1823     | Pass   | 1824     | Pass   |
| 1825                                                                 | Pass   | 1826     | Pass   | 1827     | Pass   | 1828     | Pass   |
| 1829                                                                 | Pass   | 1830     | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**