

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/184/25	Model No.: KMCRQ-10	Date: 09-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 184/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01831 To 1840	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01831 To 1840 and removed from the Lot/Batch							
1831	Pass	1832	Pass	1833	Pass	1834	Pass
1835	Pass	1836	Pass	1837	Pass	1838	Pass
1839	Pass	1840	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory