

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/226/25	Model No.: MARQ-6-40%	Date: 22-12-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 226/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22501 To 22600 And 22505A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22505A and removed from the Lot/Batch							
22501	Pass	22502	Pass	22503	Pass	22504	Pass
22505	Pass	22506	Pass	22507	Pass	22508	Pass
22509	Pass	22510	Pass	22511	Pass	22512	Pass
22513	Pass	22514	Pass	22515	Pass	22516	Pass
22517	Pass	22518	Pass	22519	Pass	22520	Pass
22521	Pass	22522	Pass	22523	Pass	22524	Pass
22525	Pass	22526	Pass	22527	Pass	22528	Pass
22529	Pass	22530	Pass	22531	Pass	22532	Pass
22533	Pass	22534	Pass	22535	Pass	22536	Pass
22537	Pass	22538	Pass	22539	Pass	22540	Pass
22541	Pass	22542	Pass	22543	Pass	22544	Pass
22545	Pass	22546	Pass	22547	Pass	22548	Pass
22549	Pass	22550	Pass	22551	Pass	22552	Pass
22553	Pass	22554	Pass	22555	Pass	22556	Pass
22557	Pass	22558	Pass	22559	Pass	22560	Pass
22561	Pass	22562	Pass	22563	Pass	22564	Pass
22565	Pass	22566	Pass	22567	Pass	22568	Pass
22569	Pass	22570	Pass	22571	Pass	22572	Pass
22573	Pass	22574	Pass	22575	Pass	22576	Pass
22577	Pass	22578	Pass	22579	Pass	22580	Pass
22581	Pass	22582	Pass	22583	Pass	22584	Pass
22585	Pass	22586	Pass	22587	Pass	22588	Pass
22589	Pass	22590	Pass	22591	Pass	22592	Pass
22593	Pass	22594	Pass	22595	Pass	22596	Pass
22597	Pass	22598	Pass	22599	Pass	22600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory