

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/104/25	Model No.: MARQ-6-50%	Date: 11-04-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 104/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10301 To 10400 And 10305A	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10305A and removed from the Lot/Batch							
10301	Pass	10302	Pass	10303	Pass	10304	Pass
10305	Pass	10306	Pass	10307	Pass	10308	Pass
10309	Pass	10310	Pass	10311	Pass	10312	Pass
10313	Pass	10314	Pass	10315	Pass	10316	Pass
10317	Pass	10318	Pass	10319	Pass	10320	Pass
10321	Pass	10322	Pass	10323	Pass	10324	Pass
10325	Pass	10326	Pass	10327	Pass	10328	Pass
10329	Pass	10330	Pass	10331	Pass	10332	Pass
10333	Pass	10334	Pass	10335	Pass	10336	Pass
10337	Pass	10338	Pass	10339	Pass	10340	Pass
10341	Pass	10342	Pass	10343	Pass	10344	Pass
10345	Pass	10346	Pass	10347	Pass	10348	Pass
10349	Pass	10350	Pass	10351	Pass	10352	Pass
10353	Pass	10354	Pass	10355	Pass	10356	Pass
10357	Pass	10358	Pass	10359	Pass	10360	Pass
10361	Pass	10362	Pass	10363	Pass	10364	Pass
10365	Pass	10366	Pass	10367	Pass	10368	Pass
10369	Pass	10370	Pass	10371	Pass	10372	Pass
10373	Pass	10374	Pass	10375	Pass	10376	Pass
10377	Pass	10378	Pass	10379	Pass	10380	Pass
10381	Pass	10382	Pass	10383	Pass	10384	Pass
10385	Pass	10386	Pass	10387	Pass	10388	Pass
10389	Pass	10390	Pass	10391	Pass	10392	Pass
10393	Pass	10394	Pass	10395	Pass	10396	Pass
10397	Pass	10398	Pass	10399	Pass	10400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory