

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/367/25	Model No.: MARQ-6-50%	Date: 19-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 367/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36601 To 36700 And 36605A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36605A and removed from the Lot/Batch							
36601	Pass	36602	Pass	36603	Pass	36604	Pass
36605	Pass	36606	Pass	36607	Pass	36608	Pass
36609	Pass	36610	Pass	36611	Pass	36612	Pass
36613	Pass	36614	Pass	36615	Pass	36616	Pass
36617	Pass	36618	Pass	36619	Pass	36620	Pass
36621	Pass	36622	Pass	36623	Pass	36624	Pass
36625	Pass	36626	Pass	36627	Pass	36628	Pass
36629	Pass	36630	Pass	36631	Pass	36632	Pass
36633	Pass	36634	Pass	36635	Pass	36636	Pass
36637	Pass	36638	Pass	36639	Pass	36640	Pass
36641	Pass	36642	Pass	36643	Pass	36644	Pass
36645	Pass	36646	Pass	36647	Pass	36648	Pass
36649	Pass	36650	Pass	36651	Pass	36652	Pass
36653	Pass	36654	Pass	36655	Pass	36656	Pass
36657	Pass	36658	Pass	36659	Pass	36660	Pass
36661	Pass	36662	Pass	36663	Pass	36664	Pass
36665	Pass	36666	Pass	36667	Pass	36668	Pass
36669	Pass	36670	Pass	36671	Pass	36672	Pass
36673	Pass	36674	Pass	36675	Pass	36676	Pass
36677	Pass	36678	Pass	36679	Pass	36680	Pass
36681	Pass	36682	Pass	36683	Pass	36684	Pass
36685	Pass	36686	Pass	36687	Pass	36688	Pass
36689	Pass	36690	Pass	36691	Pass	36692	Pass
36693	Pass	36694	Pass	36695	Pass	36696	Pass
36697	Pass	36698	Pass	36699	Pass	36700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory