

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/380/25	Model No.: MARQ-6-50%	Date: 27-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 380/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 37901 To 38000 And 37905A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 37905A and removed from the Lot/Batch							
37901	Pass	37902	Pass	37903	Pass	37904	Pass
37905	Pass	37906	Pass	37907	Pass	37908	Pass
37909	Pass	37910	Pass	37911	Pass	37912	Pass
37913	Pass	37914	Pass	37915	Pass	37916	Pass
37917	Pass	37918	Pass	37919	Pass	37920	Pass
37921	Pass	37922	Pass	37923	Pass	37924	Pass
37925	Pass	37926	Pass	37927	Pass	37928	Pass
37929	Pass	37930	Pass	37931	Pass	37932	Pass
37933	Pass	37934	Pass	37935	Pass	37936	Pass
37937	Pass	37938	Pass	37939	Pass	37940	Pass
37941	Pass	37942	Pass	37943	Pass	37944	Pass
37945	Pass	37946	Pass	37947	Pass	37948	Pass
37949	Pass	37950	Pass	37951	Pass	37952	Pass
37953	Pass	37954	Pass	37955	Pass	37956	Pass
37957	Pass	37958	Pass	37959	Pass	37960	Pass
37961	Pass	37962	Pass	37963	Pass	37964	Pass
37965	Pass	37966	Pass	37967	Pass	37968	Pass
37969	Pass	37970	Pass	37971	Pass	37972	Pass
37973	Pass	37974	Pass	37975	Pass	37976	Pass
37977	Pass	37978	Pass	37979	Pass	37980	Pass
37981	Pass	37982	Pass	37983	Pass	37984	Pass
37985	Pass	37986	Pass	37987	Pass	37988	Pass
37989	Pass	37990	Pass	37991	Pass	37992	Pass
37993	Pass	37994	Pass	37995	Pass	37996	Pass
37997	Pass	37998	Pass	37999	Pass	38000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory