

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/379/25	Model No.: MARQ-6-50%	Date: 27-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 379/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 37801 To 37900 And 37805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 37805A and removed from the Lot/Batch							
37801	Pass	37802	Pass	37803	Pass	37804	Pass
37805	Pass	37806	Pass	37807	Pass	37808	Pass
37809	Pass	37810	Pass	37811	Pass	37812	Pass
37813	Pass	37814	Pass	37815	Pass	37816	Pass
37817	Pass	37818	Pass	37819	Pass	37820	Pass
37821	Pass	37822	Pass	37823	Pass	37824	Pass
37825	Pass	37826	Pass	37827	Pass	37828	Pass
37829	Pass	37830	Pass	37831	Pass	37832	Pass
37833	Pass	37834	Pass	37835	Pass	37836	Pass
37837	Pass	37838	Pass	37839	Pass	37840	Pass
37841	Pass	37842	Pass	37843	Pass	37844	Pass
37845	Pass	37846	Pass	37847	Pass	37848	Pass
37849	Pass	37850	Pass	37851	Pass	37852	Pass
37853	Pass	37854	Pass	37855	Pass	37856	Pass
37857	Pass	37858	Pass	37859	Pass	37860	Pass
37861	Pass	37862	Pass	37863	Pass	37864	Pass
37865	Pass	37866	Pass	37867	Pass	37868	Pass
37869	Pass	37870	Pass	37871	Pass	37872	Pass
37873	Pass	37874	Pass	37875	Pass	37876	Pass
37877	Pass	37878	Pass	37879	Pass	37880	Pass
37881	Pass	37882	Pass	37883	Pass	37884	Pass
37885	Pass	37886	Pass	37887	Pass	37888	Pass
37889	Pass	37890	Pass	37891	Pass	37892	Pass
37893	Pass	37894	Pass	37895	Pass	37896	Pass
37897	Pass	37898	Pass	37899	Pass	37900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory