

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/212/25	Model No.: KFARQ-4-90%	Date: 27-12-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 212/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21101 To 21200 And 21105A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21105A and removed from the Lot/Batch							
21101	Pass	21102	Pass	21103	Pass	21104	Pass
21105	Pass	21106	Pass	21107	Pass	21108	Pass
21109	Pass	21110	Pass	21111	Pass	21112	Pass
21113	Pass	21114	Pass	21115	Pass	21116	Pass
21117	Pass	21118	Pass	21119	Pass	21120	Pass
21121	Pass	21122	Pass	21123	Pass	21124	Pass
21125	Pass	21126	Pass	21127	Pass	21128	Pass
21129	Pass	21130	Pass	21131	Pass	21132	Pass
21133	Pass	21134	Pass	21135	Pass	21136	Pass
21137	Pass	21138	Pass	21139	Pass	21140	Pass
21141	Pass	21142	Pass	21143	Pass	21144	Pass
21145	Pass	21146	Pass	21147	Pass	21148	Pass
21149	Pass	21150	Pass	21151	Pass	21152	Pass
21153	Pass	21154	Pass	21155	Pass	21156	Pass
21157	Pass	21158	Pass	21159	Pass	21160	Pass
21161	Pass	21162	Pass	21163	Pass	21164	Pass
21165	Pass	21166	Pass	21167	Pass	21168	Pass
21169	Pass	21170	Pass	21171	Pass	21172	Pass
21173	Pass	21174	Pass	21175	Pass	21176	Pass
21177	Pass	21178	Pass	21179	Pass	21180	Pass
21181	Pass	21182	Pass	21183	Pass	21184	Pass
21185	Pass	21186	Pass	21187	Pass	21188	Pass
21189	Pass	21190	Pass	21191	Pass	21192	Pass
21193	Pass	21194	Pass	21195	Pass	21196	Pass
21197	Pass	21198	Pass	21199	Pass	21200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory