

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/194/25	Model No.: KFARQ-6-50%	Date: 12-06-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 194/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19301 To 19400 And 19305A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19305A and removed from the Lot/Batch							
19301	Pass	19302	Pass	19303	Pass	19304	Pass
19305	Pass	19306	Pass	19307	Pass	19308	Pass
19309	Pass	19310	Pass	19311	Pass	19312	Pass
19313	Pass	19314	Pass	19315	Pass	19316	Pass
19317	Pass	19318	Pass	19319	Pass	19320	Pass
19321	Pass	19322	Pass	19323	Pass	19324	Pass
19325	Pass	19326	Pass	19327	Pass	19328	Pass
19329	Pass	19330	Pass	19331	Pass	19332	Pass
19333	Pass	19334	Pass	19335	Pass	19336	Pass
19337	Pass	19338	Pass	19339	Pass	19340	Pass
19341	Pass	19342	Pass	19343	Pass	19344	Pass
19345	Pass	19346	Pass	19347	Pass	19348	Pass
19349	Pass	19350	Pass	19351	Pass	19352	Pass
19353	Pass	19354	Pass	19355	Pass	19356	Pass
19357	Pass	19358	Pass	19359	Pass	19360	Pass
19361	Pass	19362	Pass	19363	Pass	19364	Pass
19365	Pass	19366	Pass	19367	Pass	19368	Pass
19369	Pass	19370	Pass	19371	Pass	19372	Pass
19373	Pass	19374	Pass	19375	Pass	19376	Pass
19377	Pass	19378	Pass	19379	Pass	19380	Pass
19381	Pass	19382	Pass	19383	Pass	19384	Pass
19385	Pass	19386	Pass	19387	Pass	19388	Pass
19389	Pass	19390	Pass	19391	Pass	19392	Pass
19393	Pass	19394	Pass	19395	Pass	19396	Pass
19397	Pass	19398	Pass	19399	Pass	19400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory