

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/A50/RQ/050/25

Model No.: KMPRQ-10-50%

Date: 02-11-2025

Type and Capacity of Extinguisher : KMPRQ-10-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg.

Batch Number : KMPRQ50%10 050/25

Batch Quantity : 20.00 Nos.

Serial Numbers : 00981 To 1000

Month of Manufacturing : Nov/25

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Burst test conducted on 00981 To 1000 and removed from the Lot/Batch

981	Pass	982	Pass	983	Pass	984	Pass
985	Pass	986	Pass	987	Pass	988	Pass
989	Pass	990	Pass	991	Pass	992	Pass
993	Pass	994	Pass	995	Pass	996	Pass
997	Pass	998	Pass	999	Pass	1000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**