

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/050/25	Model No.: KFMRQ-45	Date: 16-11-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 050/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02451 To 2500	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.2005A and which is removed from the batch (41st batch)							
2451	Pass	2452	Pass	2453	Pass	2454	Pass
2455	Pass	2456	Pass	2457	Pass	2458	Pass
2459	Pass	2460	Pass	2461	Pass	2462	Pass
2463	Pass	2464	Pass	2465	Pass	2466	Pass
2467	Pass	2468	Pass	2469	Pass	2470	Pass
2471	Pass	2472	Pass	2473	Pass	2474	Pass
2475	Pass	2476	Pass	2477	Pass	2478	Pass
2479	Pass	2480	Pass	2481	Pass	2482	Pass
2483	Pass	2484	Pass	2485	Pass	2486	Pass
2487	Pass	2488	Pass	2489	Pass	2490	Pass
2491	Pass	2492	Pass	2493	Pass	2494	Pass
2495	Pass	2496	Pass	2497	Pass	2498	Pass
2499	Pass	2500	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory