

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/001/26	Model No.: KFKHQ-9	Date: 04-01-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 001/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00001 To 10	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00001 To 10 and removed from the Lot/Batch							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory