

|                                   |                                                                        |                  |
|-----------------------------------|------------------------------------------------------------------------|------------------|
| TC No.: D6/A90/RQ/024/25          | Model No.: KFDRQ-6-90%                                                 | Date: 30-12-2025 |
| Type and Capacity of Extinguisher | : KFDRQ-6-90%-Kanex DCP CP ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFDRQ90%6 024/25                                                     |                  |
| Batch Quantity                    | : 101.00 Nos.                                                          |                  |
| Serial Numbers                    | : 02301 To 2400 And 2305A                                              |                  |
| Month of Manufacturing            | : Dec/25                                                               |                  |
| Date of Inspection                | : 30-12-2025                                                           |                  |

| Sr. Nos. | Cl. No.    | Tests and Inspection                                                                                                                                                                                                                      | Requirements                                                                                                                 | Sampling                 | Observation |
|----------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|--------------------------|-------------|
| 1        | 5.1.4      | Extinguishing Agent                                                                                                                                                                                                                       | MAP 90% Dry Powder Confirms to IS 4308                                                                                       | One                      | Pass        |
| 2        | 5.2        | Propellants                                                                                                                                                                                                                               | The propellants for stored pressure and cartridge operated extinguishers shall be air, carbon dioxide and nitrogen.          | All                      | CO2         |
| 3        | 5.3.2      | Filling tolerance                                                                                                                                                                                                                         | ±2% by Mass                                                                                                                  | One                      | Pass        |
| 4        | 6.1        | Hydro test of the body                                                                                                                                                                                                                    | Test pressure 35 bar, Hold for 2.5 Min.                                                                                      | All                      | Pass        |
| 5        | 7.2        | Effective discharge time                                                                                                                                                                                                                  | Approved fire rating is 6A:183B, hence Min. duration is 15sec.<br>Sr. No. :02301                                             | One                      | 20 SEC.     |
| 6        | 7.2        | Bulk range of Discharge                                                                                                                                                                                                                   | Approved fire rating is 6A:183B, hence Min. bulk range is 2m.Sr. No. :02301                                                  | One                      | 4 Mtr.      |
| 7        | 3.8        | Percentage of Discharge                                                                                                                                                                                                                   | Min. 85%, Sr. No. :02301                                                                                                     | One                      | 94%         |
| 8        | 7.4.1      | Retention of Charge following partial discharge                                                                                                                                                                                           | The second pressure or weight shall not be less than 75% of the first after interruption of the discharge.<br>Sr. No. :02302 | One                      | 94%         |
| 9        | 9.2        | Construction Requirements                                                                                                                                                                                                                 | 120gm CO2 gas cartridge shall conform to IS 4947 and other requirements of IS 15683:2018                                     | All                      | Pass        |
| 10       | 9.2.2      | Burst test of body                                                                                                                                                                                                                        | Burst pressure shall be 55 bar if break from body and shall be 80 bar if break from welding .<br>Sr. No. :02305A             | One                      | 138 Bar     |
| 11       | 9.3        | Carrying Handle                                                                                                                                                                                                                           | Requirements as per IS 15683:2018                                                                                            | All                      | Pass        |
| 12       | 9.4        | Mounting Test                                                                                                                                                                                                                             | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 13       | 9.5        | Valves and Closures                                                                                                                                                                                                                       | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 14       | 9.8        | Hose Assemblies                                                                                                                                                                                                                           | Length of hose is 465mm and shall withstands a hydro pressure of 55 bar for at least 30 seconds.                             | One                      | 59 Bar      |
| 15       | 9.9        | Method of Operation                                                                                                                                                                                                                       | Max. force required to operate the valve with full hand is 200N                                                              | One                      | 168N        |
| 16       | 9.10.1     | Safety Locking Devices                                                                                                                                                                                                                    | Force required to remove safety locking device is 20N-100N                                                                   | Two                      | 52N & 57N   |
| 17       | 9.10.6     | Safety Locking Devices                                                                                                                                                                                                                    | Tamper indicator shall break with force not more than 70N & other requiremet as per IS 15683:2018                            | Two                      | 51N & 56N   |
| 18       | 10.1       | Color for body                                                                                                                                                                                                                            | Shade No. 538(P.O. Red) of IS 5 and blue band to be provided                                                                 | All                      | Pass        |
| 19       | --         | Anticorrosive treatment & Painting                                                                                                                                                                                                        | Phosphate treatment followed by Pure polyester Powder coating with DFT not less than 50μ.                                    | All                      | (65-90)μ    |
| 20       | 10.2.1     | Marking                                                                                                                                                                                                                                   | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 21       | 10.2.2     | Operating Instructions                                                                                                                                                                                                                    | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 22       | 10.2.3     | Code symbols                                                                                                                                                                                                                              | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 23       | 10.3       | Inspection instruction                                                                                                                                                                                                                    | As per IS 15683:2018                                                                                                         | All                      | Pass        |
| 24       | Type tests | 1)Resistance to Temp. changes<br>2)Impact test<br>3)Vibrations test<br>4)External Corrosion test 5)Tapping test<br>6)Intermittent discharge 7)Maximum Service Pressure 8)Crushing test<br>9)Pressure cycling<br>10) Fire performance test | As per IS 15683:2018                                                                                                         | As per Scheme of testing | Pass        |
| 25       | --         | Dimensions and Completeness                                                                                                                                                                                                               | Diameter: 150±5mm, Height: 540mm Approx, Thickness: 1.6mm Approx                                                             | All                      | Pass        |

**Remarks: This is to certify that the ABC dry Powder (Cartridge operated) Type Fire Extinguisher of Capacity 6 kg. meets and confirms to the requirements of IS 15683:2018.**



**Authorized Signatory**