

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/089/25	Model No.: KFARQ-4-50%	Date: 21-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 089/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08801 To 8900 And 8805A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8805A and removed from the Lot/Batch							
8801	Pass	8802	Pass	8803	Pass	8804	Pass
8805	Pass	8806	Pass	8807	Pass	8808	Pass
8809	Pass	8810	Pass	8811	Pass	8812	Pass
8813	Pass	8814	Pass	8815	Pass	8816	Pass
8817	Pass	8818	Pass	8819	Pass	8820	Pass
8821	Pass	8822	Pass	8823	Pass	8824	Pass
8825	Pass	8826	Pass	8827	Pass	8828	Pass
8829	Pass	8830	Pass	8831	Pass	8832	Pass
8833	Pass	8834	Pass	8835	Pass	8836	Pass
8837	Pass	8838	Pass	8839	Pass	8840	Pass
8841	Pass	8842	Pass	8843	Pass	8844	Pass
8845	Pass	8846	Pass	8847	Pass	8848	Pass
8849	Pass	8850	Pass	8851	Pass	8852	Pass
8853	Pass	8854	Pass	8855	Pass	8856	Pass
8857	Pass	8858	Pass	8859	Pass	8860	Pass
8861	Pass	8862	Pass	8863	Pass	8864	Pass
8865	Pass	8866	Pass	8867	Pass	8868	Pass
8869	Pass	8870	Pass	8871	Pass	8872	Pass
8873	Pass	8874	Pass	8875	Pass	8876	Pass
8877	Pass	8878	Pass	8879	Pass	8880	Pass
8881	Pass	8882	Pass	8883	Pass	8884	Pass
8885	Pass	8886	Pass	8887	Pass	8888	Pass
8889	Pass	8890	Pass	8891	Pass	8892	Pass
8893	Pass	8894	Pass	8895	Pass	8896	Pass
8897	Pass	8898	Pass	8899	Pass	8900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory