

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/M/RQ/012/25        | Model No.: KFDMSRQ-6                                           | Date: 19-08-2025 |
| Type and Capacity of Extinguisher | : KFDMSRQ-6-Kanex D Type Metal SP Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFDMSRQ6 012/25                                              |                  |
| Batch Quantity                    | : 21.00 Nos.                                                   |                  |
| Serial Numbers                    | : 00221 To 240 And 225A                                        |                  |
| Month of Manufacturing            | : Aug/25                                                       |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 225A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 221                                                         | Pass   | 222      | Pass   | 223      | Pass   | 224      | Pass   |
| 225                                                         | Pass   | 226      | Pass   | 227      | Pass   | 228      | Pass   |
| 229                                                         | Pass   | 230      | Pass   | 231      | Pass   | 232      | Pass   |
| 233                                                         | Pass   | 234      | Pass   | 235      | Pass   | 236      | Pass   |
| 237                                                         | Pass   | 238      | Pass   | 239      | Pass   | 240      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**