

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/035/26	Model No.: MARQ-6-50%	Date: 17-01-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 035/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03401 To 3500 And 3405A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3405A and removed from the Lot/Batch							
3401	Pass	3402	Pass	3403	Pass	3404	Pass
3405	Pass	3406	Pass	3407	Pass	3408	Pass
3409	Pass	3410	Pass	3411	Pass	3412	Pass
3413	Pass	3414	Pass	3415	Pass	3416	Pass
3417	Pass	3418	Pass	3419	Pass	3420	Pass
3421	Pass	3422	Pass	3423	Pass	3424	Pass
3425	Pass	3426	Pass	3427	Pass	3428	Pass
3429	Pass	3430	Pass	3431	Pass	3432	Pass
3433	Pass	3434	Pass	3435	Pass	3436	Pass
3437	Pass	3438	Pass	3439	Pass	3440	Pass
3441	Pass	3442	Pass	3443	Pass	3444	Pass
3445	Pass	3446	Pass	3447	Pass	3448	Pass
3449	Pass	3450	Pass	3451	Pass	3452	Pass
3453	Pass	3454	Pass	3455	Pass	3456	Pass
3457	Pass	3458	Pass	3459	Pass	3460	Pass
3461	Pass	3462	Pass	3463	Pass	3464	Pass
3465	Pass	3466	Pass	3467	Pass	3468	Pass
3469	Pass	3470	Pass	3471	Pass	3472	Pass
3473	Pass	3474	Pass	3475	Pass	3476	Pass
3477	Pass	3478	Pass	3479	Pass	3480	Pass
3481	Pass	3482	Pass	3483	Pass	3484	Pass
3485	Pass	3486	Pass	3487	Pass	3488	Pass
3489	Pass	3490	Pass	3491	Pass	3492	Pass
3493	Pass	3494	Pass	3495	Pass	3496	Pass
3497	Pass	3498	Pass	3499	Pass	3500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory