

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/198/25	Model No.: KFARQ-4-90%	Date: 24-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 198/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19701 To 19800 And 19705A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19705A and removed from the Lot/Batch							
19701	Pass	19702	Pass	19703	Pass	19704	Pass
19705	Pass	19706	Pass	19707	Pass	19708	Pass
19709	Pass	19710	Pass	19711	Pass	19712	Pass
19713	Pass	19714	Pass	19715	Pass	19716	Pass
19717	Pass	19718	Pass	19719	Pass	19720	Pass
19721	Pass	19722	Pass	19723	Pass	19724	Pass
19725	Pass	19726	Pass	19727	Pass	19728	Pass
19729	Pass	19730	Pass	19731	Pass	19732	Pass
19733	Pass	19734	Pass	19735	Pass	19736	Pass
19737	Pass	19738	Pass	19739	Pass	19740	Pass
19741	Pass	19742	Pass	19743	Pass	19744	Pass
19745	Pass	19746	Pass	19747	Pass	19748	Pass
19749	Pass	19750	Pass	19751	Pass	19752	Pass
19753	Pass	19754	Pass	19755	Pass	19756	Pass
19757	Pass	19758	Pass	19759	Pass	19760	Pass
19761	Pass	19762	Pass	19763	Pass	19764	Pass
19765	Pass	19766	Pass	19767	Pass	19768	Pass
19769	Pass	19770	Pass	19771	Pass	19772	Pass
19773	Pass	19774	Pass	19775	Pass	19776	Pass
19777	Pass	19778	Pass	19779	Pass	19780	Pass
19781	Pass	19782	Pass	19783	Pass	19784	Pass
19785	Pass	19786	Pass	19787	Pass	19788	Pass
19789	Pass	19790	Pass	19791	Pass	19792	Pass
19793	Pass	19794	Pass	19795	Pass	19796	Pass
19797	Pass	19798	Pass	19799	Pass	19800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory