

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/016/26	Model No.: KFARQ-6-50%	Date: 17-01-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 016/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01501 To 1600 And 1505A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1505A and removed from the Lot/Batch							
1501	Pass	1502	Pass	1503	Pass	1504	Pass
1505	Pass	1506	Pass	1507	Pass	1508	Pass
1509	Pass	1510	Pass	1511	Pass	1512	Pass
1513	Pass	1514	Pass	1515	Pass	1516	Pass
1517	Pass	1518	Pass	1519	Pass	1520	Pass
1521	Pass	1522	Pass	1523	Pass	1524	Pass
1525	Pass	1526	Pass	1527	Pass	1528	Pass
1529	Pass	1530	Pass	1531	Pass	1532	Pass
1533	Pass	1534	Pass	1535	Pass	1536	Pass
1537	Pass	1538	Pass	1539	Pass	1540	Pass
1541	Pass	1542	Pass	1543	Pass	1544	Pass
1545	Pass	1546	Pass	1547	Pass	1548	Pass
1549	Pass	1550	Pass	1551	Pass	1552	Pass
1553	Pass	1554	Pass	1555	Pass	1556	Pass
1557	Pass	1558	Pass	1559	Pass	1560	Pass
1561	Pass	1562	Pass	1563	Pass	1564	Pass
1565	Pass	1566	Pass	1567	Pass	1568	Pass
1569	Pass	1570	Pass	1571	Pass	1572	Pass
1573	Pass	1574	Pass	1575	Pass	1576	Pass
1577	Pass	1578	Pass	1579	Pass	1580	Pass
1581	Pass	1582	Pass	1583	Pass	1584	Pass
1585	Pass	1586	Pass	1587	Pass	1588	Pass
1589	Pass	1590	Pass	1591	Pass	1592	Pass
1593	Pass	1594	Pass	1595	Pass	1596	Pass
1597	Pass	1598	Pass	1599	Pass	1600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory