

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/A50/RQ/004/26	Model No.: KMPRQ-5-50%	Date: 24-01-2026
Type and Capacity of Extinguisher	: KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMPRQ50%5 004/26	
Batch Quantity	: 100.00 Nos.	
Serial Numbers	: 00301 To 400	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00301 To 400 and removed from the Lot/Batch							
301	Pass	302	Pass	303	Pass	304	Pass
305	Pass	306	Pass	307	Pass	308	Pass
309	Pass	310	Pass	311	Pass	312	Pass
313	Pass	314	Pass	315	Pass	316	Pass
317	Pass	318	Pass	319	Pass	320	Pass
321	Pass	322	Pass	323	Pass	324	Pass
325	Pass	326	Pass	327	Pass	328	Pass
329	Pass	330	Pass	331	Pass	332	Pass
333	Pass	334	Pass	335	Pass	336	Pass
337	Pass	338	Pass	339	Pass	340	Pass
341	Pass	342	Pass	343	Pass	344	Pass
345	Pass	346	Pass	347	Pass	348	Pass
349	Pass	350	Pass	351	Pass	352	Pass
353	Pass	354	Pass	355	Pass	356	Pass
357	Pass	358	Pass	359	Pass	360	Pass
361	Pass	362	Pass	363	Pass	364	Pass
365	Pass	366	Pass	367	Pass	368	Pass
369	Pass	370	Pass	371	Pass	372	Pass
373	Pass	374	Pass	375	Pass	376	Pass
377	Pass	378	Pass	379	Pass	380	Pass
381	Pass	382	Pass	383	Pass	384	Pass
385	Pass	386	Pass	387	Pass	388	Pass
389	Pass	390	Pass	391	Pass	392	Pass
393	Pass	394	Pass	395	Pass	396	Pass
397	Pass	398	Pass	399	Pass	400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory