

HYDRO PRESSURE TEST

TC No.: HPT/W45/RQ/005/26	Model No.: KFWRQ-45	Date: 01-02-2026
Type and Capacity of Extinguisher	: KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFWRQ45 005/26	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00021 To 25 And 25A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25A and removed from the Lot/Batch							
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory