

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/045/26     | Model No.: MARQ-6-50%                                          | Date: 24-01-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 045/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 04401 To 4500 And 4405A                                      |                  |
| Month of Manufacturing            | : Jan/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 4405A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 4401                                                         | Pass   | 4402     | Pass   | 4403     | Pass   | 4404     | Pass   |
| 4405                                                         | Pass   | 4406     | Pass   | 4407     | Pass   | 4408     | Pass   |
| 4409                                                         | Pass   | 4410     | Pass   | 4411     | Pass   | 4412     | Pass   |
| 4413                                                         | Pass   | 4414     | Pass   | 4415     | Pass   | 4416     | Pass   |
| 4417                                                         | Pass   | 4418     | Pass   | 4419     | Pass   | 4420     | Pass   |
| 4421                                                         | Pass   | 4422     | Pass   | 4423     | Pass   | 4424     | Pass   |
| 4425                                                         | Pass   | 4426     | Pass   | 4427     | Pass   | 4428     | Pass   |
| 4429                                                         | Pass   | 4430     | Pass   | 4431     | Pass   | 4432     | Pass   |
| 4433                                                         | Pass   | 4434     | Pass   | 4435     | Pass   | 4436     | Pass   |
| 4437                                                         | Pass   | 4438     | Pass   | 4439     | Pass   | 4440     | Pass   |
| 4441                                                         | Pass   | 4442     | Pass   | 4443     | Pass   | 4444     | Pass   |
| 4445                                                         | Pass   | 4446     | Pass   | 4447     | Pass   | 4448     | Pass   |
| 4449                                                         | Pass   | 4450     | Pass   | 4451     | Pass   | 4452     | Pass   |
| 4453                                                         | Pass   | 4454     | Pass   | 4455     | Pass   | 4456     | Pass   |
| 4457                                                         | Pass   | 4458     | Pass   | 4459     | Pass   | 4460     | Pass   |
| 4461                                                         | Pass   | 4462     | Pass   | 4463     | Pass   | 4464     | Pass   |
| 4465                                                         | Pass   | 4466     | Pass   | 4467     | Pass   | 4468     | Pass   |
| 4469                                                         | Pass   | 4470     | Pass   | 4471     | Pass   | 4472     | Pass   |
| 4473                                                         | Pass   | 4474     | Pass   | 4475     | Pass   | 4476     | Pass   |
| 4477                                                         | Pass   | 4478     | Pass   | 4479     | Pass   | 4480     | Pass   |
| 4481                                                         | Pass   | 4482     | Pass   | 4483     | Pass   | 4484     | Pass   |
| 4485                                                         | Pass   | 4486     | Pass   | 4487     | Pass   | 4488     | Pass   |
| 4489                                                         | Pass   | 4490     | Pass   | 4491     | Pass   | 4492     | Pass   |
| 4493                                                         | Pass   | 4494     | Pass   | 4495     | Pass   | 4496     | Pass   |
| 4497                                                         | Pass   | 4498     | Pass   | 4499     | Pass   | 4500     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**