

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/008/26	Model No.: MARQ-4-50%	Date: 17-01-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 008/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00701 To 800 And 705A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 705A and removed from the Lot/Batch							
701	Pass	702	Pass	703	Pass	704	Pass
705	Pass	706	Pass	707	Pass	708	Pass
709	Pass	710	Pass	711	Pass	712	Pass
713	Pass	714	Pass	715	Pass	716	Pass
717	Pass	718	Pass	719	Pass	720	Pass
721	Pass	722	Pass	723	Pass	724	Pass
725	Pass	726	Pass	727	Pass	728	Pass
729	Pass	730	Pass	731	Pass	732	Pass
733	Pass	734	Pass	735	Pass	736	Pass
737	Pass	738	Pass	739	Pass	740	Pass
741	Pass	742	Pass	743	Pass	744	Pass
745	Pass	746	Pass	747	Pass	748	Pass
749	Pass	750	Pass	751	Pass	752	Pass
753	Pass	754	Pass	755	Pass	756	Pass
757	Pass	758	Pass	759	Pass	760	Pass
761	Pass	762	Pass	763	Pass	764	Pass
765	Pass	766	Pass	767	Pass	768	Pass
769	Pass	770	Pass	771	Pass	772	Pass
773	Pass	774	Pass	775	Pass	776	Pass
777	Pass	778	Pass	779	Pass	780	Pass
781	Pass	782	Pass	783	Pass	784	Pass
785	Pass	786	Pass	787	Pass	788	Pass
789	Pass	790	Pass	791	Pass	792	Pass
793	Pass	794	Pass	795	Pass	796	Pass
797	Pass	798	Pass	799	Pass	800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory