

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/020/26	Model No.: KFKHQ-6	Date: 01-02-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 020/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00191 To 200 And 195A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 195A and removed from the Lot/Batch							
191	Pass	192	Pass	193	Pass	194	Pass
195	Pass	196	Pass	197	Pass	198	Pass
199	Pass	200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory