

HYDRO PRESSURE TEST

TC No.: HPT/W45/RQ/004/26	Model No.: KFWRQ-45	Date: 08-01-2026
Type and Capacity of Extinguisher	: KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFWRQ45 004/26	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00016 To 20 And 20A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20A and removed from the Lot/Batch							
16	Pass	17	Pass	18	Pass	19	Pass
20	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory