

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/062/26	Model No.: MARQ-6-50%	Date: 07-02-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 062/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06101 To 6200 And 6105A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6105A and removed from the Lot/Batch							
6101	Pass	6102	Pass	6103	Pass	6104	Pass
6105	Pass	6106	Pass	6107	Pass	6108	Pass
6109	Pass	6110	Pass	6111	Pass	6112	Pass
6113	Pass	6114	Pass	6115	Pass	6116	Pass
6117	Pass	6118	Pass	6119	Pass	6120	Pass
6121	Pass	6122	Pass	6123	Pass	6124	Pass
6125	Pass	6126	Pass	6127	Pass	6128	Pass
6129	Pass	6130	Pass	6131	Pass	6132	Pass
6133	Pass	6134	Pass	6135	Pass	6136	Pass
6137	Pass	6138	Pass	6139	Pass	6140	Pass
6141	Pass	6142	Pass	6143	Pass	6144	Pass
6145	Pass	6146	Pass	6147	Pass	6148	Pass
6149	Pass	6150	Pass	6151	Pass	6152	Pass
6153	Pass	6154	Pass	6155	Pass	6156	Pass
6157	Pass	6158	Pass	6159	Pass	6160	Pass
6161	Pass	6162	Pass	6163	Pass	6164	Pass
6165	Pass	6166	Pass	6167	Pass	6168	Pass
6169	Pass	6170	Pass	6171	Pass	6172	Pass
6173	Pass	6174	Pass	6175	Pass	6176	Pass
6177	Pass	6178	Pass	6179	Pass	6180	Pass
6181	Pass	6182	Pass	6183	Pass	6184	Pass
6185	Pass	6186	Pass	6187	Pass	6188	Pass
6189	Pass	6190	Pass	6191	Pass	6192	Pass
6193	Pass	6194	Pass	6195	Pass	6196	Pass
6197	Pass	6198	Pass	6199	Pass	6200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory