

HYDRO PRESSURE TEST

TC No.: HPT/A2/K/HQ/004/25	Model No.: KFKHQ-2	Date: 05-05-2025
Type and Capacity of Extinguisher	: KFKHQ-2-Kanex F Class Kitchen Fire Extinguisher Cap. 2 Ltr.	
Batch Number	: KFKHQ2 004/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00031 To 40	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00031 To 40 and removed from the Lot/Batch							
31	Pass	32	Pass	33	Pass	34	Pass
35	Pass	36	Pass	37	Pass	38	Pass
39	Pass	40	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory