

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/044/26	Model No.: MARQ-6-50%	Date: 24-01-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 044/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04301 To 4400 And 4305A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4305A and removed from the Lot/Batch							
4301	Pass	4302	Pass	4303	Pass	4304	Pass
4305	Pass	4306	Pass	4307	Pass	4308	Pass
4309	Pass	4310	Pass	4311	Pass	4312	Pass
4313	Pass	4314	Pass	4315	Pass	4316	Pass
4317	Pass	4318	Pass	4319	Pass	4320	Pass
4321	Pass	4322	Pass	4323	Pass	4324	Pass
4325	Pass	4326	Pass	4327	Pass	4328	Pass
4329	Pass	4330	Pass	4331	Pass	4332	Pass
4333	Pass	4334	Pass	4335	Pass	4336	Pass
4337	Pass	4338	Pass	4339	Pass	4340	Pass
4341	Pass	4342	Pass	4343	Pass	4344	Pass
4345	Pass	4346	Pass	4347	Pass	4348	Pass
4349	Pass	4350	Pass	4351	Pass	4352	Pass
4353	Pass	4354	Pass	4355	Pass	4356	Pass
4357	Pass	4358	Pass	4359	Pass	4360	Pass
4361	Pass	4362	Pass	4363	Pass	4364	Pass
4365	Pass	4366	Pass	4367	Pass	4368	Pass
4369	Pass	4370	Pass	4371	Pass	4372	Pass
4373	Pass	4374	Pass	4375	Pass	4376	Pass
4377	Pass	4378	Pass	4379	Pass	4380	Pass
4381	Pass	4382	Pass	4383	Pass	4384	Pass
4385	Pass	4386	Pass	4387	Pass	4388	Pass
4389	Pass	4390	Pass	4391	Pass	4392	Pass
4393	Pass	4394	Pass	4395	Pass	4396	Pass
4397	Pass	4398	Pass	4399	Pass	4400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory