

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/038/26	Model No.: MARQ-6-40%	Date: 09-02-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 038/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03701 To 3800 And 3705A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3705A and removed from the Lot/Batch							
3701	Pass	3702	Pass	3703	Pass	3704	Pass
3705	Pass	3706	Pass	3707	Pass	3708	Pass
3709	Pass	3710	Pass	3711	Pass	3712	Pass
3713	Pass	3714	Pass	3715	Pass	3716	Pass
3717	Pass	3718	Pass	3719	Pass	3720	Pass
3721	Pass	3722	Pass	3723	Pass	3724	Pass
3725	Pass	3726	Pass	3727	Pass	3728	Pass
3729	Pass	3730	Pass	3731	Pass	3732	Pass
3733	Pass	3734	Pass	3735	Pass	3736	Pass
3737	Pass	3738	Pass	3739	Pass	3740	Pass
3741	Pass	3742	Pass	3743	Pass	3744	Pass
3745	Pass	3746	Pass	3747	Pass	3748	Pass
3749	Pass	3750	Pass	3751	Pass	3752	Pass
3753	Pass	3754	Pass	3755	Pass	3756	Pass
3757	Pass	3758	Pass	3759	Pass	3760	Pass
3761	Pass	3762	Pass	3763	Pass	3764	Pass
3765	Pass	3766	Pass	3767	Pass	3768	Pass
3769	Pass	3770	Pass	3771	Pass	3772	Pass
3773	Pass	3774	Pass	3775	Pass	3776	Pass
3777	Pass	3778	Pass	3779	Pass	3780	Pass
3781	Pass	3782	Pass	3783	Pass	3784	Pass
3785	Pass	3786	Pass	3787	Pass	3788	Pass
3789	Pass	3790	Pass	3791	Pass	3792	Pass
3793	Pass	3794	Pass	3795	Pass	3796	Pass
3797	Pass	3798	Pass	3799	Pass	3800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory