

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/046/25	Model No.: MARQ-9-50%	Date: 27-12-2025
Type and Capacity of Extinguisher	: MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ50%9 046/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04501 To 4600 And 4505A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4505A and removed from the Lot/Batch							
4501	Pass	4502	Pass	4503	Pass	4504	Pass
4505	Pass	4506	Pass	4507	Pass	4508	Pass
4509	Pass	4510	Pass	4511	Pass	4512	Pass
4513	Pass	4514	Pass	4515	Pass	4516	Pass
4517	Pass	4518	Pass	4519	Pass	4520	Pass
4521	Pass	4522	Pass	4523	Pass	4524	Pass
4525	Pass	4526	Pass	4527	Pass	4528	Pass
4529	Pass	4530	Pass	4531	Pass	4532	Pass
4533	Pass	4534	Pass	4535	Pass	4536	Pass
4537	Pass	4538	Pass	4539	Pass	4540	Pass
4541	Pass	4542	Pass	4543	Pass	4544	Pass
4545	Pass	4546	Pass	4547	Pass	4548	Pass
4549	Pass	4550	Pass	4551	Pass	4552	Pass
4553	Pass	4554	Pass	4555	Pass	4556	Pass
4557	Pass	4558	Pass	4559	Pass	4560	Pass
4561	Pass	4562	Pass	4563	Pass	4564	Pass
4565	Pass	4566	Pass	4567	Pass	4568	Pass
4569	Pass	4570	Pass	4571	Pass	4572	Pass
4573	Pass	4574	Pass	4575	Pass	4576	Pass
4577	Pass	4578	Pass	4579	Pass	4580	Pass
4581	Pass	4582	Pass	4583	Pass	4584	Pass
4585	Pass	4586	Pass	4587	Pass	4588	Pass
4589	Pass	4590	Pass	4591	Pass	4592	Pass
4593	Pass	4594	Pass	4595	Pass	4596	Pass
4597	Pass	4598	Pass	4599	Pass	4600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory