

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A50/RQ/049/25     | Model No.: MARQ-4-50%                                          | Date: 17-07-2025 |
| Type and Capacity of Extinguisher | : MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ50%4 049/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 04801 To 4900 And 4805A                                      |                  |
| Month of Manufacturing            | : Jul/25                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 4805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 4801                                                         | Pass   | 4802     | Pass   | 4803     | Pass   | 4804     | Pass   |
| 4805                                                         | Pass   | 4806     | Pass   | 4807     | Pass   | 4808     | Pass   |
| 4809                                                         | Pass   | 4810     | Pass   | 4811     | Pass   | 4812     | Pass   |
| 4813                                                         | Pass   | 4814     | Pass   | 4815     | Pass   | 4816     | Pass   |
| 4817                                                         | Pass   | 4818     | Pass   | 4819     | Pass   | 4820     | Pass   |
| 4821                                                         | Pass   | 4822     | Pass   | 4823     | Pass   | 4824     | Pass   |
| 4825                                                         | Pass   | 4826     | Pass   | 4827     | Pass   | 4828     | Pass   |
| 4829                                                         | Pass   | 4830     | Pass   | 4831     | Pass   | 4832     | Pass   |
| 4833                                                         | Pass   | 4834     | Pass   | 4835     | Pass   | 4836     | Pass   |
| 4837                                                         | Pass   | 4838     | Pass   | 4839     | Pass   | 4840     | Pass   |
| 4841                                                         | Pass   | 4842     | Pass   | 4843     | Pass   | 4844     | Pass   |
| 4845                                                         | Pass   | 4846     | Pass   | 4847     | Pass   | 4848     | Pass   |
| 4849                                                         | Pass   | 4850     | Pass   | 4851     | Pass   | 4852     | Pass   |
| 4853                                                         | Pass   | 4854     | Pass   | 4855     | Pass   | 4856     | Pass   |
| 4857                                                         | Pass   | 4858     | Pass   | 4859     | Pass   | 4860     | Pass   |
| 4861                                                         | Pass   | 4862     | Pass   | 4863     | Pass   | 4864     | Pass   |
| 4865                                                         | Pass   | 4866     | Pass   | 4867     | Pass   | 4868     | Pass   |
| 4869                                                         | Pass   | 4870     | Pass   | 4871     | Pass   | 4872     | Pass   |
| 4873                                                         | Pass   | 4874     | Pass   | 4875     | Pass   | 4876     | Pass   |
| 4877                                                         | Pass   | 4878     | Pass   | 4879     | Pass   | 4880     | Pass   |
| 4881                                                         | Pass   | 4882     | Pass   | 4883     | Pass   | 4884     | Pass   |
| 4885                                                         | Pass   | 4886     | Pass   | 4887     | Pass   | 4888     | Pass   |
| 4889                                                         | Pass   | 4890     | Pass   | 4891     | Pass   | 4892     | Pass   |
| 4893                                                         | Pass   | 4894     | Pass   | 4895     | Pass   | 4896     | Pass   |
| 4897                                                         | Pass   | 4898     | Pass   | 4899     | Pass   | 4900     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**