

TC No.: A6/K/HQ/014/26	Model No.: KFKHQ-6	Date: 30-01-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 014/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00131 To 140 And 135A	
Month of Manufacturing	: Jan/26	
Date of Inspection	: 30-01-2026	

Sr. Nos.	Cl. No.	Tests and Inspection	Requirements	Sampling	Observation
1	5.1.5	Extinguishing Agent	Wet Chemical (Blend of Potassium acetate, citrate or carbonate)	One	Pass
2	5.2	Propellants	The propellants for stored pressure and cartridge operated extinguishers shall be air, carbon dioxide and nitrogen.	All	Nitrogen
3	5.3.2	Filling tolerance	+5% by Volume	One	Pass
4	6.1	Hydro test of the body	Test pressure 35 bar, Hold for 2.5 Min.	All	Pass
5	7.2	Effective discharge time	Approved fire rating is 25F, hence Min. duration is 13 sec. Sr. No. :00131	One	25 SEC.
6	7.2	Bulk range of Discharge	Approved fire rating is 25F, hence Min. bulk range is 2m. Sr. No. :00131	One	4 Mtr.
7	3.7	Percentage of Discharge	Not less than 90%, Sr. No. :00131	One	97%
8	7.4.1	Retention of Charge following partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the discharge. Sr. No. :00132	One	94%
9	7.4.2	Leakage Test	Inverted Glass Jar/ Soap Solution	All	Pass
10	9.2	Construction Requirements	As per IS 15683:2018	All	Pass
11	9.2.2	Burst test of body	Burst pressure shall be 55 bar if break from body and shall be 80 bar if break from welding . Sr. No. :00135A	One	89 Bar
12	9.3	Carrying Handle	Requirements as per IS 15683:2018	All	Pass
13	9.4	Mounting Test	As per IS 15683:2018	All	Pass
14	9.5	Valves and Closures	As per IS 15683:2018	All	Pass
15	9.8	Hose Assemblies	Length of hose is 400 mm and shall withstands a hydro pressure of 55 bar for at least 30 seconds.	One	63 Bar
16	9.9	Method of Operation	Max. force required to operate the valve with full hand is 200N	One	167N
17	9.10.1	Safety Locking Devices	Force required to remove safety locking device is 20N-100N	Two	65N & 70N
18	9.10.6	Safety Locking Devices	Tamper indicator shall break with force not more than 70N & other requiremet as per IS 15683:2018	Two	57N & 62N
19	10.1	Color for body	Smooth Finish	All	Pass
20	10.2.1	Marking	As per IS 15683:2018	All	Pass
21	10.2.2	Operating Instructions	As per IS 15683:2018	All	Pass
22	10.2.3	Code symbols	As per IS 15683:2018	All	Pass
23	10.3	Inspection instruction	As per IS 15683:2018	All	Pass
24	Type tests	1)Resistance to Temp. changes 2)Impact test 3)Vibrations test 4)External Corrosion test 5)Internal Corrosion test 6)Intermittent discharge 7)Maximum Service Pressure 8)Crushing test 9)Pressure cycling 10) Fire performance test	As per IS 15683:2018	As per Scheme of testing	Pass
25	--	Dimensions and Completeness	Diameter: 150±5mm, Height: 500mm Approx, Thickness: Made up of 1mm sheet	All	Pass

Remarks: This is to certify that the Kitchen type Fire Extinguisher of Capacity 6 Ltr. meets and confirms to the requirements of IS 15683:2018.



Authorized Signatory