

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/A50/RQ/019/25	Model No.: KMPRQ-2-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KMPRQ-2-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMPRQ50%2 019/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00361 To 380	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00361 To 380 and removed from the Lot/Batch							
361	Pass	362	Pass	363	Pass	364	Pass
365	Pass	366	Pass	367	Pass	368	Pass
369	Pass	370	Pass	371	Pass	372	Pass
373	Pass	374	Pass	375	Pass	376	Pass
377	Pass	378	Pass	379	Pass	380	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory