

# HYDRO PRESSURE TEST

|                                   |                                                                        |                  |
|-----------------------------------|------------------------------------------------------------------------|------------------|
| TC No.: HPT/D9/A90/RQ/006/25      | Model No.: KFDRQ-9-90%                                                 | Date: 13-07-2025 |
| Type and Capacity of Extinguisher | : KFDRQ-9-90%-Kanex DCP CP ABC Dry Powder Fire Extinguisher Cap. 9 Kg. |                  |
| Batch Number                      | : KFDRQ90%9 006/25                                                     |                  |
| Batch Quantity                    | : 101.00 Nos.                                                          |                  |
| Serial Numbers                    | : 00501 To 600 And 505A                                                |                  |
| Month of Manufacturing            | : Jul/25                                                               |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 505A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 501                                                         | Pass   | 502      | Pass   | 503      | Pass   | 504      | Pass   |
| 505                                                         | Pass   | 506      | Pass   | 507      | Pass   | 508      | Pass   |
| 509                                                         | Pass   | 510      | Pass   | 511      | Pass   | 512      | Pass   |
| 513                                                         | Pass   | 514      | Pass   | 515      | Pass   | 516      | Pass   |
| 517                                                         | Pass   | 518      | Pass   | 519      | Pass   | 520      | Pass   |
| 521                                                         | Pass   | 522      | Pass   | 523      | Pass   | 524      | Pass   |
| 525                                                         | Pass   | 526      | Pass   | 527      | Pass   | 528      | Pass   |
| 529                                                         | Pass   | 530      | Pass   | 531      | Pass   | 532      | Pass   |
| 533                                                         | Pass   | 534      | Pass   | 535      | Pass   | 536      | Pass   |
| 537                                                         | Pass   | 538      | Pass   | 539      | Pass   | 540      | Pass   |
| 541                                                         | Pass   | 542      | Pass   | 543      | Pass   | 544      | Pass   |
| 545                                                         | Pass   | 546      | Pass   | 547      | Pass   | 548      | Pass   |
| 549                                                         | Pass   | 550      | Pass   | 551      | Pass   | 552      | Pass   |
| 553                                                         | Pass   | 554      | Pass   | 555      | Pass   | 556      | Pass   |
| 557                                                         | Pass   | 558      | Pass   | 559      | Pass   | 560      | Pass   |
| 561                                                         | Pass   | 562      | Pass   | 563      | Pass   | 564      | Pass   |
| 565                                                         | Pass   | 566      | Pass   | 567      | Pass   | 568      | Pass   |
| 569                                                         | Pass   | 570      | Pass   | 571      | Pass   | 572      | Pass   |
| 573                                                         | Pass   | 574      | Pass   | 575      | Pass   | 576      | Pass   |
| 577                                                         | Pass   | 578      | Pass   | 579      | Pass   | 580      | Pass   |
| 581                                                         | Pass   | 582      | Pass   | 583      | Pass   | 584      | Pass   |
| 585                                                         | Pass   | 586      | Pass   | 587      | Pass   | 588      | Pass   |
| 589                                                         | Pass   | 590      | Pass   | 591      | Pass   | 592      | Pass   |
| 593                                                         | Pass   | 594      | Pass   | 595      | Pass   | 596      | Pass   |
| 597                                                         | Pass   | 598      | Pass   | 599      | Pass   | 600      | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**