



# Warranty Certificate

Date: 27-02-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Ingram Micro India Private Limited**Warranty Start Date:** 27-02-2026**Warranty End Date:** 26-02-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                              | Quantity | Sr. Nos.            |
|--------|---------------------------------------------------------------|----------|---------------------|
| 1      | KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. | 6        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/008628 Dated: 27-02-2026 P.O.No. IM-CPTS-13667** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**