

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/069/26     | Model No.: MARQ-6-50%                                          | Date: 12-02-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 069/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 06801 To 6900 And 6805A                                      |                  |
| Month of Manufacturing            | : Feb/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 6805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 6801                                                         | Pass   | 6802     | Pass   | 6803     | Pass   | 6804     | Pass   |
| 6805                                                         | Pass   | 6806     | Pass   | 6807     | Pass   | 6808     | Pass   |
| 6809                                                         | Pass   | 6810     | Pass   | 6811     | Pass   | 6812     | Pass   |
| 6813                                                         | Pass   | 6814     | Pass   | 6815     | Pass   | 6816     | Pass   |
| 6817                                                         | Pass   | 6818     | Pass   | 6819     | Pass   | 6820     | Pass   |
| 6821                                                         | Pass   | 6822     | Pass   | 6823     | Pass   | 6824     | Pass   |
| 6825                                                         | Pass   | 6826     | Pass   | 6827     | Pass   | 6828     | Pass   |
| 6829                                                         | Pass   | 6830     | Pass   | 6831     | Pass   | 6832     | Pass   |
| 6833                                                         | Pass   | 6834     | Pass   | 6835     | Pass   | 6836     | Pass   |
| 6837                                                         | Pass   | 6838     | Pass   | 6839     | Pass   | 6840     | Pass   |
| 6841                                                         | Pass   | 6842     | Pass   | 6843     | Pass   | 6844     | Pass   |
| 6845                                                         | Pass   | 6846     | Pass   | 6847     | Pass   | 6848     | Pass   |
| 6849                                                         | Pass   | 6850     | Pass   | 6851     | Pass   | 6852     | Pass   |
| 6853                                                         | Pass   | 6854     | Pass   | 6855     | Pass   | 6856     | Pass   |
| 6857                                                         | Pass   | 6858     | Pass   | 6859     | Pass   | 6860     | Pass   |
| 6861                                                         | Pass   | 6862     | Pass   | 6863     | Pass   | 6864     | Pass   |
| 6865                                                         | Pass   | 6866     | Pass   | 6867     | Pass   | 6868     | Pass   |
| 6869                                                         | Pass   | 6870     | Pass   | 6871     | Pass   | 6872     | Pass   |
| 6873                                                         | Pass   | 6874     | Pass   | 6875     | Pass   | 6876     | Pass   |
| 6877                                                         | Pass   | 6878     | Pass   | 6879     | Pass   | 6880     | Pass   |
| 6881                                                         | Pass   | 6882     | Pass   | 6883     | Pass   | 6884     | Pass   |
| 6885                                                         | Pass   | 6886     | Pass   | 6887     | Pass   | 6888     | Pass   |
| 6889                                                         | Pass   | 6890     | Pass   | 6891     | Pass   | 6892     | Pass   |
| 6893                                                         | Pass   | 6894     | Pass   | 6895     | Pass   | 6896     | Pass   |
| 6897                                                         | Pass   | 6898     | Pass   | 6899     | Pass   | 6900     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**